

**Addendum #4
September 22, 2020**

RFP 20-1015

Water Damage Repair

**Housing Authority of Kansas City
920 Main Street, Suite 701
Kansas City, MO 64105**

NOTICE TO ALL RESPONDENTS

The following addendum to the Request for Proposal comprises this addendum and is hereby made part of the RFP.

Additional information is provided below in response to questions for this project:

1. Can you clarify the expectation on painting for this project? Should we paint corner to corner and floor to ceiling on anything that is repaired?

a) Feathering the paint for approximately 2' around the repair is acceptable.

There are no other changes at this time.

This written response is being submitted to the Housing Authority of Kansas City, Missouri in conjunction with the Request for Proposal (RFP) 20-1015 dated September 4, 2020.

I hereby represent that I am a duly authorized agent for the company identified below, AND THAT I HAVE RECEIVED THE ADDENDUM #4.

Company: _____

Authorized Signatory: _____
Printed Name

Title: _____

Signature: _____

Date: _____

NOTE: THIS COVER PAGE MUST BE ATTACHED TO THE WRITTEN BID SUBMITTED IN RESPONSE TO THIS RFP.